

COMPLIANCE TESTED by berkeley analytical VOC Emission Test Certificate

Product Name: Titebond DuraMaster Color Sealants - 8051

Product Sample Information				
Company:	Franklin International			
Company Website:	www.franklininternational.com			
Product Type:	Joint Sealants			
Date Produced:	3/23/2023			

Certificate Information				
Certificate No:	230613-02			
Certified By:	far. J			
	Raja S. Tannous, Laboratory Director			
Date:	June 13, 2023			

Reference Standard: California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017 (Emission testing method for CA Specification 01350)

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario ¹	Individual VOCs of Concern ²		Formaldehyde ³		TVOC⁴
	Criterion	Compliant?	Criterion	Compliant?	Range
School Classroom	≤½ Chronic REL	YES	≤9.0 μg/m³	YES	≤ 0.5 mg/m³
Private Office	≤½ Chronic REL	YES	≤9.0 μg/m³	YES	≤ 0.5 mg/m³

Product Coverage⁵: 8420 g/m² (See manufacturer letter attached)

- $1. \ Exposure \ scenarios \ \& \ product \ quantities \ for \ classroom \ \& \ office \ are \ defined \ in \ Tables \ 4-2-4-5 \ (CDPH \ Std. \ Mtd. \ V1.2-2017)$
- 2. Maximum allowable concentrations of individual target VOCs are specified in Table 4-1 (ibid.)
- 3. Maximum allowable formaldehyde concentration is ≤9 µg/m³, effective Jan 1, 2012; previous limit was ≤16.5 µg/m³ (ibid.)
- 4. Informative only; predicted TVOC Range in three categories, i.e., ≤0.5 mg/m³, >0.5 4.9 mg/m³, and ≥5.0 mg/m³
- 5. Informative and applicable only to tests of wet-applied products; grams of sample applied per square meter of substrate

Standards & Codes Recognizing CDPH Standard Method V1.2 (partial list)

- USGBC LEED Version 4/4.1, BD&C, ID&C, Residential BD&C Multifamily
- The WELL Building Standard, WELL v2, Feature X06
- ANSI/GBI 01-2019 Green Globes Assessment Protocol

Narrative: Franklin International selected a sample representative of its Titebond DuraMaster Color Sealants - 8051 product and submitted it on 5/17/2023 for testing. Berkeley Analytical measured and evaluated the emissions of VOCs from this sample following CDPH/EHLB/Standard Method V1.2-2017. The results of the test are presented in Berkeley Analytical report, 338-060-01A-Jun1323.

Berkeley Analytical is an independent, third-party laboratory specializing in the analysis of organic chemicals emitted by and contained in building products, finishes, furniture, and consumer products. We are an ISO/IEC 17025 accredited laboratory (IAS, <u>TL-383</u>); all standards used in performing this test are in Berkeley Analytical's scope of accreditation.

DISCLAIMER: THIS CERTIFICATE OF COMPLIANCE AFFIRMS THAT: 1) A SAMPLE OF THE LISTED PRODUCT WAS TESTED ACCORDING TO THE REFERENCED STANDARD; 2) THE MEASURED VOC EMISSIONS FROM THE SAMPLE WERE EVALUATED FOR THE DEFINED EXPOSURE SCENARIO(S); AND 3) THE RESULTS MEET THE ACCEPTANCE CRITERIA OF THE REFERENCED STANDARD(S). BERKELEY ANALYTICAL IS NOT RESPONSIBLE FOR ANY CLAIMS REGARDING A PRODUCT OR PRODUCTS ENTERED INTO COMMERCE THAT MAY BE BASED ON THIS TEST. BERKELEY ANALYTICAL PROVIDES THIS CERTIFICATE OF COMPLIANCE "AS IS" WITHOUT WARRANTY OF ANY KIND, EITHER EXPRESSED OR IMPLIED, INCLUDING BUT NOT LIMITED TO, THE IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR ANY PURPOSE.

Franklin International

May 10, 2023

Dear Mr. Hodgson,

RE: VOC Emission Testing; CDPH Standard Method v1.2; Titebond Duramaster Color Sealants application calculations

Below are the rationale and the calculations for quantity of Titebond Duramaster Color Sealants that would be used in the standard classroom and standard private office defined in CDPH Standard Method v1.2.

Classroom - Room size is 40 feet long x 24 feet wide

Since this is an interior sealant, application is assumed to be sealing baseboard trim (I bead), crown molding (2 beads), and around an 80" x 32" door and four 48" x 36" windows (1 bead around 2 sides and top of the door and 1 bead completely around each of the four windows) in a classroom.

Total linear feet of sealant required is 454 feet. One 10.1 oz. cartridge seals 31 linear feet using a ¼" bead, so 14.6 cartridges are needed per classroom, meaning 147.46 oz. or 1.15 gallons of sealant

One gallon of product weighs 10.85 lb.

1.15 gallons x 10.85 lb./gallon = 12.48 lb. of sealant used in the classroom.

Office – Room size is 12 feet long x 10 feet wide

Since this is an interior sealant, application is assumed to be sealing baseboard trim (I bead), crown molding (2 beads), and around an 80" x 32" door and two 48" x 36" windows (1 bead around 2 sides and top of the door and 1 bead completely around each of the windows) in the office room.

Total linear feet of sealant required is 174 feet. One 10.1 oz cartridge of this sealant seals on average 31 linear feet using a ¼" bead so 5.6 cartridges are needed per office, meaning 56.56 oz. or 0.44 gallons.

0.44 gallons x 10.85 lb./gallon = **4.77 lb. of sealant used in the office.**

I hope this information meets your needs. Please let me know if you have any additional questions or concerns.

Sincerely,

Ben Ward Franklin International